



NOTE:

WHEN THE WATER MAIN IS ABOVE THE SANITARY SEWER, BUT WITH LESS THAN 24" CLEARANCE, OR WHEN THE SANITARY SEWER IS ABOVE THE WATER MAIN, BOTH THE WATER MAIN AND THE SANITARY SEWER LINE SHALL BE CONSTRUCTED OF DUCTILE IRON PIPE WITH JOINTS EQUIVALENT TO WATER MAIN STANDARDS FOR A MINIMUM LATERAL DISTANCE, MEASURED AT RIGHT ANGLES TO THE SEWER, OF 10 FEET ON EACH SIDE OF THE CROSSING.



RELATION OF WATER MAINS TO SANITARY SEWER MAINS

1	2/28/05	JEC	REVISED FROM WSACC			
No.	Date	By	REVISION			
	Drawn By:	Checked By:	Approved By:	Date	Sht	of
	JEC	PLK	MSH	10/07		