



June 24, 2011

**ADDENDUM NO. 2 –
CIDDLE CREEK WATER TREATMENT PLANT LAGOONS SLUDGE REMOVAL
Project No. 2011-040**

This Addendum shall be incorporated into the bid documents.

1. The deadline for submission of bids has been extended to Wednesday, July 6, 2011 at 2:00 p.m. in Conference Room C of the Alfred M. Brown Operations Center.
2. The page numbers in the Table of Contents were incorrect, please replace it with the attached page.
3. As a reminder, please submit a notarized Debarred Firms Certification Form on page 12 with your bid.
4. As a reminder, please provide a 5% bid Security along with your bid.
5. The material to be dewatered and disposed is Alum-type sludge.
6. The Coddle Creek Water Treatment Plant Facility is located at 6935 Davidson Highway (same as NC Highway 73), Concord, NC 28027. The facility is located at the end of the Private Drive on the left.
7. Refer to the Instructions To Bidders, Section 4 - Examination of Contract Documents and Site regarding any necessary investigation for visiting the facility. Contractors may collect any samples that are necessary to conduct their own inquiry.
8. There is not a boat available on site at the treatment facility.
9. For proposed site visits, complete the following
 - (a) send an email to churchwellj@concordnc.gov at least 24 hours prior to your scheduled visit, and
 - (b) telephone the water treatment facility at 704.920.5163 at least 1 hour prior to your representative's arrival to notify the operator on duty regarding your scheduled visit.
10. As stated in the Project Special Conditions, each sludge lagoon has a volume of approximately 3 million gallons.
11. Contractor will need to provide their own power supply at the site.
12. There is space available at the site for equipment staging near the lagoons. Contractor will use all necessary measures to prevent erosion as stated in the Bid Documents and shall restore the site upon project completion to that similar to its original condition or better.

CITY OF CONCORD

A handwritten signature in black ink that reads "Jana E Churchwell".

Jana E Churchwell, EI
Project Engineer

*Engineering Department
Alfred M. Brown Operations Center*

City of Concord • 850 Warren C. Coleman Blvd. • P.O. Box 308 • Concord, North Carolina 28026
(704) 920-5425 • Fax (704) 786-4521 • TDD 1-800-735-8262 • www.ci.concord.nc.us

TABLE OF CONTENTS

Coddle Creek Sludge Removal

TITLE PAGE.....	1
NORTH CAROLINA 811	2
TABLE OF CONTENTS.....	3

BIDS, AGREEMENTS, AND NOTICES

INVITATION TO BID	4
INSTRUCTION TO BIDDERS	5
DEBARRED FIRMS CERTIFICATION FORM	12
EXHIBIT A – BID FORM	13
NOTICE OF AWARD.....	18
NOTICE TO PROCEED	19
CONSTRUCTION CONTRACT	20
APPLICATION FOR PAYMENT	28
CONTRACT CHANGE ORDER.....	30
CERTIFICATE OF INFRASTRUCTURE COMPLETION.....	31
FIELD ORDER	32
NORTH CAROLINA SALES TAX REPORT	33

EXHIBIT B - PROJECT SPECIAL CONDITIONS

PROJECT AVAILABILITY	34
EROSION CONTROL PROVISIONS.....	34
PROJECT AND PAYMENT DETAILS.....	34

EXHIBIT C – GENERAL CONDITIONS

35