



HILLGROVE WATER TREATMENT PLANT
EMERGENCY GENERATOR SET
BID NO. 2376

Addendum #1 – 1/31/19

ITEM 1:

EXHIBIT A – BID FORM

Page 16

6. Bidder agrees that all work will be completed and ready for final payment in accordance with Paragraph 14.13 of the General Conditions within **180** days from the date of notice to proceed.

ITEM 2:

EXHIBIT B – SPECIFICATIONS

Page 23

PART 2 – PRODUCTS

2.2 ENGINE-GENERATOR SET

- B. The electric power generating system shall consist of one 600 kW, 750.0 kVA, 0.8 power factor, 600 volts, **Delta Corner Grounded**, 3-Phase, 4 wire, 60 hertz generator systems. Motor starting at 90% rated sustained voltage will not be accepted. Generator set shall be rated for Standby applications with typical usage of 500 hours per year.

ITEM 3:

STANDARD FORM CONSTRUCTION CONTRACT (sample)

Page 53

Definitions:

Sec. 5. Term.

All work as set forth in the Scope of Services in Exhibit "B" shall be completed within **sixty (180)** calendar days of the Commencement Date. The date that is **sixty (180)** calendar days from the Commencement Date shall be the "Completion Date."

End of Addendum #1