

**CHELWOOD DR. AND CHADBOURNE AVE.
CULVERT REPLACEMENTS
(REBID)**

**PROJECT NO. 2017-026
BID NO. 2401**

ADDENDUM 1

May 22, 2019

1. Bid Due Date:

- Bid due date in sheet 5 of the bid documents should be changed to May 29, 2019 at 10:00 AM.

2. Culvert Wingwalls:

- Only precast gravity block walls will be acceptable for the culverts wingwalls, such as Stone Strong or Redi-Rock Gravity Walls systems. Wall systems relying on geogrid for stability will not be acceptable.

End of Addendum 1